

Confirmation

LEED v4.1

On 20 November 2020, Eurofins Product Testing A/S received a sample of coating with the product name:

PROLATEX

supplied by

Farby KABE Polska Sp. z o.o.

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, ISO 11890-2 testing standards (See test report no. 392-2020-00529901_B_EN and no. 392-2020-00529902_XG_EN).

The test results of the tested sample indicate that the product qualifies for LEED v4.1 BETA (July 2020) specifications on VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of Option 2 of LEED v4.1 BETA (July 2020) by not exceeding the LCI values mentioned in the German AgBB Testing and Evaluation Scheme (2018), showing an overall R-value below 1 and having a TVOC according to EN 16516 below 0.5 mg/m³ and a formaldehyde emission below 10 µg/m³ after 28 days.

VOC content specifications in LEED EQ credit "Low-emitting products":

- The requirements of the EU Decopaint Directive 2004/42/CE for Interior Paints having a VOC content below 30 g/L

9 February 2021



Rasmus Verdier
Analytical Service Manager



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.